Please return report to:



City of Wenatchee, Environmental Division

Attn. Julie Michael, Quality Control Technician P.O. Box 519, 1350 McKittrick Street Wenatchee, WA 98807-0519 509-888-3227 or Fax 509-888-3201

BACKFLOW PREVENTION ASSEMBLY TEST REPORT

ACCOUNT #:			Test Due Before:	
NAME OF PREMISE:			Comm	ercial 🗆 Residential 🗆
SERVICE ADDRESS:			CITY:	ZIP:
PHONE:				
LOCATION OF ASSEMBLY:				
DOWNSTREAM PROCESS:			DCVA □ RPBA	□ PVBA □ OTHER
NEW INSTALL □ EXISTING □ REPLACEMENT □ OLD SER. #PROPER INSTALLATION? YES □ NO □				
MAKE OF ASSEMBLY: SERIAL #:				
IS THIS ASSEMBLY ON THE LIST OF ASSEMBLIES APPROVED FOR USE IN WASHINGTON STATE?				
INITIAL TEST	DCVA / RPBA CHECK VALVE NO.1	DCVA / RPBA CHECK VALVE NO.2	RPBA OPENED AT PSID	<u>PVBA/SVBA</u> AIR INLET
IESI	LEAKED CLOSED TIGHT	LEAKED □ CLOSED TIGHT □	#1 CHECKPSID	OPENED ATPSID
PASSED □ FAILED □	PSI	PSID	AIR GAP OK?	OPENED FULLY
FAILED	151	1515		CHECK VALVE HELD ATPSID
NEW	CLEAN REPLACE PART	CLEAN REPLACE PART	CLEAN REPLACE PART	CLEAN REPLACE PART
PARTS AND REPAIRS				
TEST AFTER REPAIRS	CLOSED TIGHT □	CLOSED TIGHT □	OPENED ATPSID	AIR INLET PSID
PASSED □ FAILED □	PSI	DPSID	#1 CHECKPSID	CHK VALVEPSID OPENED FULLY □
SHUT OFF VALVES CLOSED TIGHTLY? SOV #1 yes \(\pri \) no \(\pri \) n/a \(\pri \) SOV #2 yes \(\pri \) no \(\pri \)				
AIR GAP INSPECTION: Required minimum air gap separation provided? Yes No Detector Meter Reading				
REMARKS: LINE PRESSUREPSI				
CONFINED SPACE? I certify that this report is accurate, and I have used WAC 246-290-490 approved test methods and test equipment.				
	1	•		
TESTERS SIGNATURE:DATE				
TESTERS NAME PRINTED: TESTERS PHONE # ()				
		_	DATE	
FINAL TEST BY:CERT. NODATE				
CALIBRATION DATE /_ /_ GAUGE # MODEL SERVICE RESTORED? YES □ NO □				